

STATE OF ALASKA
DEPARTMENT OF MILITARY & VETERANS AFFAIRS
FACILITY MANAGEMENT OFFICE

ADDENDUM NUMBER 01

DATE: 6 April, 2010

PROJECT NO.: 02A8010044

PROJECT NAME: Anchorage Armory D-101/103 Renovate Family Services

PROJECT LOCATION:

DESCRIPTION: The following description of work elements is issued for the purpose of clarifying the work or work simplification. This addendum supersedes conflicting drawings, work descriptions or specifications of Contract documents and shall form a part thereof.

CHANGES TO SPECIFICATIONS:

PREBID QUESTION:

1. The attached requirements only calls for moving air around to serve the new offices. The included plans sent with the RFP show that the existing perimeter small offices in this area have individual baseboard fin tube control. Do they want us to rezone the baseboard to add a zone in each of the two new exterior offices?
2. Location for wall mount emergency light is not shown.

ANSWER TO QUESTION:

1. No, rezoning is not required for the baseboard, only the sensor in the D103 for the base board control needs to be moved out of the new private office and into the open office space. The supply and return air needs to be modified to allow occupants of (D101D,E,F; D103D,E,F) to have air in their offices.
2. Add wall mount emergency light on the common area side of D101E and D103E.

All other terms and conditions remain the same.

THIS ADDENDA MUST BE ACKNOWLEDGED ON SPC-002 FOR THIS PROJECT.